

Remediation Results for Water outlets used for consumption or food preparation that exceeded the Lead Action Level in the initial test.

School No.	Sample ID	Location	Remediation	Lead Concentration After Remediation (PPB)	Notes
1	01-1KIT-S-FP-01	Food Preparation	Faucets & Bubblers Replaced	3.9	
1	01-1-504-E-DW	Drinking Water Fountain	Faucets & Bubblers Replaced	2.5	
1	01-1-503-E-DW	Drinking Water Fountain	Faucets & Bubblers Replaced	2	
1	01-1-502-S-DW	Drinking Water Fountain	Faucets & Bubblers Replaced	2.9	
1	01-2-409-E-DW	Drinking Water Fountain	Faucets & Bubblers Replaced	4.9	
1	01-2-408-E-DW	Drinking Water Fountain	Faucets & Bubblers Replaced	4.7	
1	01-2-404-N-DW	Drinking Water Fountain	Faucets & Bubblers Replaced	6.2	
4	4-3FL-320-S-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
4	4-GFL-KIT-S-KT1	Kitchen Kettle	Faucets Replaced	32.7	Shut-off.
5	5-3-HGR-E-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
5	5-1-KIT-E-FP-1	Food Preparation	Faucets Replaced	124	Shut-off.
7	7-1-HW-125-W-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
7	7-1-ELEHW-E-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	

7	7-2-HW217-N-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
7	7-3-ELEHW-W-DW2	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
7	7-4-ELEHW-E-DW1	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
7	7-4-ELEHW-E-DW2	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
7	7-G-G4-W-TL-1	Teacher Lounge	Faucets Replaced	N.D.	
14	14- B-HGT02-N-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
14	14-B-10-W-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
16	16-2-TR-W-TS	Teacher Lounge	Faucets Replaced Filters Installed	3.3	
18	18-1-H104-NW-DW-1	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
19	19-B-K1C-W-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
19	19-B-KIA-W-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	2	
20	20-G-Kit-N-KC-1	Food Preparation	Faucets Replaced	N.D.	
27	27-1-KIT-E-KT-R	Kitchen Kettle	Faucets Replaced	2.3	

28	28-1-CAF-SWC-1-R	Drinking Water Fountain	Changed Valve. Filter Installed	N.D.	
81	81-1-CAF2-N-DW	Drinking Water Fountain	Faucets & Bubblers Replaced	6.6	
81	81-1-CAF2-E-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
81	82-2-H253-W-DW-2	Drinking Water Fountain	Faucets & Bubblers Replaced	3.8	
82	82-1-H127-W-DW-2	Drinking Water Fountain	Faucets & Bubblers Replaced	11.5	
82	82-2-H184-S-DW	Drinking Water Fountain	Faucets & Bubblers Replaced	9.1	
82	82-2-H170-S-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
83	83-1-PA-N-DW-2	Drinking Water Fountain	Faucets & Bubblers Replaced	6.3	
83	83-1-GYM-W-DW-2	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
84	84-2-CAF-W-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
86	86-1-CAF-N-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	3	
86	86-1-KIT-N-FP-1	Food Preparation	Faucets Replaced	10.1	
86	86-1-KIT-W-FP-2	Food Preparation	Faucets Replaced	N.D.	
86	86-1-KIT-E-FP-3	Food Preparation	Faucets Replaced	8.4	
86	86-1-KIT-E-FP-4	Food Preparation	Faucets Replaced	10.1	
86	86-1-4-W-TF	Teacher Lounge	Faucets Replaced Filters Installed	N.D.	

86	86-1-Nur-S-NS	Nurse Room	Faucets Replaced	6.4	
87	87-1-KIT-W-FP-3	Food Preparation	Faucets Replaced	2.9	
87	87-1-CAF-E-DW-1	Drinking Water Fountain	Faucets & Bubblers Replaced	5.3	
87	87-1-CAF-E-DW-2	Drinking Water Fountain	Faucets & Bubblers Replaced	8.1	
87	87-1-H102-N-DW-1	Drinking Water Fountain	Faucets & Bubblers Replaced	6.3	
87	87-1-SHR-N-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
87	87-1-HGYM-S-DW-2	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	
87	87-1-GLR-W-DW	Drinking Water Fountain	Faucets & Bubblers Replaced	6.4	
87	87-2-TR-N-TF	Teacher Lounge	Faucets Replaced Filters Installed	2	
87	87-2-H202-N-DW-1	Drinking Water Fountain	Faucets & Bubblers Replaced	4.7	
89	89-2-H102-N-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	2	
89	89-2-H103-N-DW	Drinking Water Fountain	Faucets & Bubblers Replaced Filters Installed	N.D.	

N.D.= None Detected

Note: Other water outlets not used for consumption were tested to gather information;
a sign "Not for drinking" was posted in all locations that exceeded the lead action level.